

RFP ADDENDUM #1
Date of Addendum: June 30,2021

NOTICE TO ALL POTENTIAL RESPONDENTS

The Request for Proposals (RFP) is modified as set forth in this Addendum. The original RFP Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the RFP. Respondent shall take this Addendum into consideration when preparing and submitting its Proposal.

PROPOSAL SUBMITTAL DEADLINE

The Proposal submittal deadline remains the same and is not changed by this Addendum.

THE REPLACEMENT AND UPGRADE OF HVAC CONTROLS FOR THE SHERMAN SCHOOL

Item	Section	Description of Change
1.1	Alternate	Include an alternate price for the deduction of the NAE 55 in your submittal.
1.2	Alternate	Include an alternate price for replacing all controllers. Continue to use the existing end devices.
1.3	Addendum	Add Start,Stop,Status,Alarm to the new controls platform for REF 3,4,5
1.4	Addendum	Add Start,Stop,Status,Alarm and Set points to the new controls platform for RTU 1
1.5	Addendum	Inspect and verify all end devices

A signed copy of the addendum is required to be included with the bid submission.

Signature_____ Name/Title_____

END OF ADDENDUM